

PHONE CALL CONFIRMATION



DEVITA & ASSOCIATES, INC.

Post Office Box 1596
Greenville, SC 29602
(864)232-6642
FAX (864)242-4878

Date: July 16, 2008
Sheet _____

DAI Job No. 08106-008
Client No. _____

Project Name: TSC – Millbrook, AL
Date and Time: July 16, 2008 – 12:50PM
Talked With: Captain D. Campbell
Of: Millbrook Fire Department
Telephone No. 334-285-6707 (p) 334-285-0307 (f)

Local L.D. Placed Received

THIS CONFIRMATION SHOULD BE CHECKED BY ALL CONCERNED FOR OMISSIONS, DELETIONS, AMENDMENTS, ETC., AND ANY CORRECTION OR DISCREPANCY SHOULD BE PROMPTLY CALLED TO THE ATTENTION OF THE UNDERSIGNED.

Captain Campbell returned the writer's call regarding the review comment for dedicated branch circuits for the emergency lighting throughout the facility. The following was discussed.

- Captain Campbell noted the emergency lights are to be circuited to dedicated circuits instead of circuiting to the local lighting circuits for the project. Captain Campbell noted this allows them to conduct their annual inspections while minimizing the impact to the operation of the facility. Mr. Campbell noted that they turn off the dedicated emergency lighting circuits to make sure the emergency lights are working properly while minimizing the amount of lights they turn off in the store.
- Captain Campbell noted the main concern for the emergency lighting is when the power to the building goes out. They are not as concerned about losing an individual lighting circuit.
- The Writer noted the emergency lighting in the Office Area, Stock Room, Mezzanine and Sales Area will be revised to comply. The circuits dedicated to feeding the emergency lighting in the separate areas will be provided with devices to lock the breakers in the 'On' position.

BY: _____

Eric. A. Mencken, P.E.

Project File: 08106-008
File Name: P20080716A.DOC